

1. SCOPE

This document details the application of SOP 2017/0406/00 (Applicable to Reyrolle LMI Ring Switches) issued by the Energy Networks Association.

2. ISSUE RECORD

This is a Reference document. The current version is held on the EN Document Library.

It is your responsibility to ensure you work to the current version.

Issue Date	Issue No.	Author	Amendment Details
June 2017	1	Patrick Dolan	Initial issue
Feb 2023	2	Patrick Dolan Clarification added to SAP Search Reference to Plant Maintenance M Document SWG-13-176 added	

3. ISSUE AUTHORITY

Author	Owner	Issue Authority
Patrick Dolan	Jon Ruiz De Aguirre	Fraser Ainslie
Lead Engineer	Substations Manager	Head of Engineering Design and Standards

4. REVIEW

This is a Reference document which has a 5 year retention period after which a reminder will be issued to review and extend retention or archive.

5. DISTRIBUTION

This document is not part of a Manual maintained by Document Control and does not have a maintained distribution list. It is published on the SP Energy Networks website.



6. CONTENTS

1
1
1
1
1
2
3
4



7.	SOP DETAILS
----	-------------

EQUIPMENT TYPE	Reyrolle LMI RMU (All variants)	
ORIGINATING COMPANY	SP Energy Networks	
DATE	5 th June 2017	
NUMBER INSTALLED IN ENERGY NETWORKS NORTH	0	
NUMBER INSTALLED IN ENERGY NETWORKS SOUTH	428	
REASON	Operation of the RMU Ring Switches is facilitated with the aid of the spring assembly to ensure that opening or closing is an independent manual operation.	
	Over time the lubrication on the internal metal tubes of the spring assembly has solidified and the spring can remain stuck in a compressed state midway through the switching operation. It can possibly drop out of the mechanism altogether. This presents the risk that the switching operation will become dependent manual.	
STATUS IN INITIATING COMPANY	All live operation of Reyrolle LMI RMU Ring switches is prohibited.	
	This restriction can be removed when the ring switches and associated spring assembly have been maintained and free movement of the mechanism has been proven.	
SPEN APPLICATION	As detailed above.	
ADDITIONAL INFORMATION	N/A	
UPDATE	N/A	
REMEDIAL ACTION	The SOP can be removed when reconditioning and re- lubrication of the spring assembly is satisfactory completed.	
	The associated instruction forms part of the maintenance manual and has document reference SWG-13-176	



8. SOP HEADER

Field Name	Field Value		Field Size		
Name (SOPXXX) *	SOP406	6			
The reason for the * Operational Restriction	Foss. Manual Dependent Open in				
Nature of the * Operational Restriction	No Live Operation of Reyrolle LMI Ring Switches		50		
Comments *	Reyrolle LMI RS Spring Assemb in the compressed condition. If t decompress it will not assist the leaving it as a manual depend o	200			
Restricted Access to * Substation Flag	Y	N	1		
SOP Impact Code * (highlight or underline the appropriate code)	0 Temporary/Impact under assess 1 Very minor operational/network imp 2 Moderate operational/network imp 3 Significant impact on system perf. costs 4 Inoperable without intervention 5 Inoperable – no cost effective solu	N/A			
SOP component type * (highlight or underline the appropriate code)	01 Bushing only 02 Circuit Breaker 03 Fixed Portion only 04 Moving Portion only 05 Switch <u>06 RMU</u> 07 Transformer only 08 Tap Changer only 09 Transformer & Bushing 10 Transformer & Tap Changer	N/A			
Search Criteria *	Manufacturer: Reyrolle Model Type: LMI/X2/JO RMU RSWs (apply SOP to both Ring Switches)		N/A		

* This denotes a Mandatory Field