

Legend


- Property Boundary
- Proposed Towers
- Proposed 275kV Powerline Route
- Creag Dhubh Power Station

Powerline Wayleave Restock

- Sitka Spruce
- Mixed Conifers
- Native Mixed Broadleaves
- Native Mixed Broadleaves/Open Ground
- Open Ground

Current Species

- Sitka Spruce
- Norway Spruce
- Scots Pine
- Noble Fir
- Douglas Fir
- Lodgepole Pine
- Japanese Larch
- Mixed Conifers
- Mixed Broadleaves
- Native Mixed Broadleaves
- Open Ground
- Other Land
- Unplanted



Native broadleaves will require planting in this area as the natural regeneration might be insufficient to reach landscape mitigation objectives.

60m OC needs to be clear of trees

Broadleaves to be a minimum of 30m from centreline

Insert 'potential' planting

Broadleaves regeneration is not anticipated to occur nearby the mature broadleaves due to the high number of deer present on site. Deer-fencing of the restocked trees will be necessary to ensure their successful establishment.

The LTFP restock does not allow for much open ground which means that the original species design will need to be modified to incorporate the wayleave.

This block of trees could be identified for long-term retention.